



Certificate of Compliance

Certificate: 1360931 (LR 111345)

Master Contract: 188330

Project: 2068655

Date Issued: 2008/08/20

Issued to: Pem-Tech, Inc.
12144 Dairy Ashford, Bldg 2
Sugar Land, TX 77478
USA
Attention: Jeff Schubert

The products listed below are eligible to bear the CSA Mark shown



Issued by: A. Holbeche, P. Eng

Authorized by: Patricia Pasemko, Operations
Manager

PRODUCTS

CLASS 4828 01 - SIGNAL APPLIANCES - - Combustible Gas Detection Instruments-For
Hazardous Locations

Class I, Groups B, C and D;

-Combustible gas stand alone stationary transmitter, Model No PT205-LEL with integral sensor P/N S-121,
input rated 14 to 30V dc, 4 Watts Max., with 4-20mA signal output.

-Combustible gas stand alone stationary transmitter, Model No PT295-LEL with integral sensor P/N S-121,
input rated 14 to 30V dc, 4 Watts Max., relay rated 5 amps @ 30V dc with 4-20mA signal output.



Certificate: 1360931 (LR 111345)

Master Contract: 188330

Project: 2068655

Date Issued: 2008/08/20

-Combustible gas stand alone stationary transmitter, Model No PT395-LEL with integral sensor P/N S-121, input rated 14 to 30V dc, 4 Watts Max., relays rated 1 amps @ 30V dc with 4-20mA signal output.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0-M91 - General Requirements-Canadian Electrical Code, Part II

CSA Std C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

CSA Std C22.2 No. 142-M1987 - Process Control Equipment

CSA Std C22.2 No. 152-M1984 - Combustible Gas Detection Instruments